#### BIOMASS BOILER INSTALLATION AND DISTRICT HEATING UPGRADE

PRESENTATION FOR

#### THE IRBEA NATIONAL BIOENERGY CONFERENCE

21 FEBRUARY 2013

Údarás na Gaeltachta Ard Oifig Na Forbacha Gaillimh









Gerard D'Arcy

#### Contents

- 1. Údarás na Gaeltachta
- 2. Why upgrade the heating system
- 3. EU Procurement Guidelines
- 4. Design Considerations
- 5. ESCO contract
- 6. Application for Funding from WDA & SEAI
- 7. Tender Process
- 8. Contract Period
- 9. Energy usage and Costs
- 10. Summary

#### Údarás na Gaeltachta

- Established in 1980
- Regional Authority responsible Economic, Social and Cultural Development
- Governing Board of 12 and 82 Staff Members
  Over 7000 people employed in Údarás na Gaeltachta Client Companies

# Údarás na Gaeltachta



# Why Upgrade

#### 1. Old Boiler

- 2. Problems with leaks on district heating
- 3. Government Directive to reduce Energy Use by 33% in Public Buildings by 2020
- 4. Need to reduce our energy imports
- 5. Help to create an awareness for the development of local indigenous renewable fuel
- 6. Help to promote local business and jobs.



# Údarás na Gaeltachta



# Údarás na Gaeltachta



# Údarás na Gaeeltachta



# Údarás na Gaeltachta





#### Data on Existing Installation:

- 1. Engineering Block , G-Comm Building and Stores built in the early 1970's
- 2. Main Building completed in 1980
- 3. The New Board Room and Business Unit completed in 2002
- 4. 700 kW oil fired Britannica boiler and GB District Heating Piping in-situ for over 34 years
- 5. Maximum Heat Load is 590 kW
- 6. Total Floor Area is 3,060 m sq.

# Old 700kW boiler



# Old 700kW boiler



# **District Heating**





# **District Heating**



# **District Heating**



### First Proposal



# EU Procurement Guidelines

- Notice on the official EU Journal on the Competitive Dialogue
- Return by Contractors with an Expression of Interest
- Contractors invited to visit the site and prepare a proposal
- A list of contractors was prepared

- Boiler size and back-up system
- Location of buffer tanks
- Location and size of wood chip store
- Location of wood chip hopper and feed system
- Access for fuel delivery truck
- District Heating piping, factory insulated plastic pipe or rigid GB.
- System of heating control

# Heat Energy Consumption







Typical caloritie values of mels

Pageloff



Toli Q LADO BZS 197 BATAL BRANASS CONTRACTSTRY, 951, 2015 MA

#### Typical calorific values of fuels

Net calorific value (CV) or Lower Heating Value (LHV) given for all fuels. This means that the latent heat of vaporization of the water vapour created by combustion is not recovered by condensation.

Puel	Net Calorific Value (CV) by moss C3/100me	Nel Calorific Value (CV) by mass kwk/kg	Bulk density ⊧g∕m <sup>3</sup>	Energy density by volume MJ/m <sup>3</sup>	6nersy density by volume kWh/m <sup>3</sup>
Wood crips (30% MC)	12.5	3.5	25ċ	3.100	870
log wood (stacked air dry: 20% MC)	14.7	4.1	350-500	5,200-7,400	1,400-2,000
Wood (solid - oven Eliya	19	57	400-600	7,600-11,400	2,100-0,200
Wood pellets	17	46	050	11,640	5, LUU
Miscantrius (bale - 25% MC)	1.5	36	140-180	1,8/10-2,100	500-650
House cost	27-31	7.3 5.6	850	23,000- 26,000	6,400 7,300
Anthracce	34	9.2	1.100	30.30P	10,100
Heisting off	42.5	11.8	<b>送相</b> 5	36,000	10,000
Natural gas (NTP)	30.1	10.6	0.9	35.2	9.8
LPR	46 9	12.9	513	23,600	6,600

© Other facts and figures

-

http://www.biomassenergycontro.org.uk/portal/page/\_pageid\_75.20041&\_dad\_portal, = 29101/2013

 Typical Calorific Value of Wood Chip (NCV) at 30% MC

- NCV by mass kWh/kg = 3.5
- Bulk Density kg/m3 = 250, (4.0m3 will store 1000kg)
- Storage Area Available 5\*5\*2 = 50 m3 or 12.5 tonne of wood chip

# **ESCO Contract**

- Concerns
- 1. Length of Contract (Capital cost + heat supply or heat supply only)
- 2. Minimum energy take
- 3. Heat supply measurement
- 4. Operation and Maintenance
- 5. Payment procedures
- 6. Biomass fuel supply
- 7. Delivery of fuel
- 8. Penalties for non delivery of heat

Steve Luker WDC

# **Grant Application**

#### Western Development Commission :

- €20,000.00 grant approved (RASLRES EU Programme)
- Developed a model ESCO Contract
- Help in the preparation of a Works Contract for the Biomass Boiler Installation

#### SEAI

 35% of the Value of the Capital Works (Better Energy Workplace 2012)

Steve Luker Fred Tottenham

#### **Tender Process**

#### Two Contracts

Biomass Boiler Capital Works & ESCO Contract

District Heating up-grade and installation of a wet heating system in two buildings.

#### Contract

Award of Contract
 Agree Completion Dates
 Appoint Specialists
 Grant Draw-down Dates

#### **Agreed Boiler House Layout**



#### New Biomass Boiler



#### New Biomass Boiler



# Oil Fired back-up boiler



#### Ash from Biomass Boiler















# **Energy Usage and Costs**



# Energy Usage & Costs





- New 300kW high efficiency biomass boiler replacing a 700kW oil fired unit
- Reduced peak load on the system
- More efficient district heat distribution
- Lower running cost
- With grants a pay-back will be achieved in 3.5 years
- Overall the response from staff members on the new heating system has been positive

#### Summary

#### Lessons Learned

- Back-up system essential
- Zone heating areas to reduce peak loading and improve efficiency
- Put procedures in place during times of fuel delivery
- Ensure the flow temperature from the back-up boiler is not set too low.
- Plastic cover over the external heating ducts will protect the pipes and brackets from rusting

# Final Word

#### Thanks